



F9MV 04 – Install and Inspect Air Handling and Extraction Units

This Unit comprises of the following National Occupational Standards (NOS)

SUMMES21

Install industrial and commercial heating & ventilating systems, equipment and components



Overview

This unit is about installing heating systems and components and involves conducting the appropriate soundness testing of systems and components, and the appropriate specified testing procedures during or after the installation of components.

The person carrying out the work must understand how various components relate to each other within the systems being installed.

SUMMES21

Install industrial and commercial heating & ventilating systems, equipment and components

Performance criteria

- You must be able to:*
- P1 confirm that the customer is aware that job information on all key aspects of the installation process is available
 - P2 confirm that all materials, tools and equipment necessary for the installation process will be available as required
 - P3 arrange safe storage provision for materials, tools and equipment, which meet industry requirements
 - P4 confirm that all preparatory work to meet the installation requirements of systems and components has been carried out
 - P5 confirm that the materials, tools and equipment required for the installation processes are fit for their intended purpose
 - P6 assemble system components using work methods that conform to industry requirements
 - P7 position system components to conform to the system design requirement
 - P8 fix system components using methods that conform to industry requirements
 - P9 connect system components to systems and input service connections using methods that meet industry requirements
 - P10 carry out the installation processes in line with industry requirements, minimising damage to customer property and building features
 - P11 report to the immediate job supervisor, line manager or customer in accordance with industry requirements any circumstances that affect the progress of the installation
 - P12 confirm the integrity of the installed system using specified testing procedures
 - P13 take precautionary actions to prevent the unauthorised use of un-commissioned systems and components

SUMMES21

Install industrial and commercial heating & ventilating systems, equipment and components

Knowledge and understanding

You need to know and understand:

- K1 how to measure and record site details for installation purposes
- K2 the industry practices and work standards for installing system components
- K3 the positioning and fixing requirements for system components which conform to the system design and intended functions
- K4 the procedures required for connecting to input services or connecting into existing systems
- K5 methods of working which protect the building fabric, customer property and existing systems or components
- K6 job management structures and methods of reporting and recording job progress or problems delaying progress
- K7 the care and maintenance requirements of tools and equipment, and the checks required to confirm they are in a safe condition
- K8 the range of tests used to confirm the soundness of systems and components and how to use the range of specified testing procedures
- K9 what precautionary actions are required during installation and testing

SUMMES21

Install industrial and commercial heating & ventilating systems, equipment and components

Developed by SummitSkills

Version number 1

Date approved October 2008

Indicative review date October 2010

Validity Current

Status Original

Originating organisation SummitSkills

Original URN M21

Relevant occupations Building and construction; Skilled Trades Occupations

Suite Mechanical Engineering Services

Key words Install, component test procedure

SUMMES25

Inspect and test mechanical systems, equipment and components



Overview

This unit is about carrying out pre-commissioning checks and tests on systems.

The person carrying out the work must be able to undertake the various checks and tests necessary before the system is brought into operation.

They are required to check the operation and correct position of components. They must also carry out tests to ensure there are no leaks and undertake cleaning or flushing of the system.

In the case of ductwork, there is a specified, permissible level of air leakage.

It is important that they are aware of the effect that isolating part of a system has on the full system.

SUMMES25

Inspect and test mechanical systems, equipment and components

Performance criteria

- You must be able to:*
- P1 confirm that the system or components installation complies with industry requirements
 - P2 check that input services to the system components are suited to their intended purpose
 - P3 check system or components for soundness using procedures that comply with industry
 - P4 carry out pre-commissioning tests and checks in accordance with industry requirements
 - P5 check that the system cleanliness, additives and charging comply with industry

SUMMES25

Inspect and test mechanical systems, equipment and components

Knowledge and understanding

You need to know and understand:

- K1 the procedures, equipment and legislative requirements for applying specified tests to systems
- K2 the methods of establishing that input services adequately supply all components within the system
- K3 the methods of connecting components to systems
- K4 the actions to take where pre-commissioning checks or tests reveal basic or complex system or component defects
- K5 how to complete pre-commissioning documentation confirming the safe pre-commissioning of systems and components

SUMMES25

Inspect and test mechanical systems, equipment and components

Developed by SummitSkills

Version number 1

Date approved October 2008

Indicative review date October 2010

Validity Current

Status Original

Originating organisation SummitSkills

Original URN M25

Relevant occupations Building and construction; Skilled Trades Occupations

Suite Mechanical Engineering Services

Key words pre-commissioning check, clean & flush, leaks

EUSDSG3.43

Decommission heating & ventilation systems, equipment and components



Overview

This unit is about de-commissioning systems, ready for further work or long-term isolation. If the system is to be permanently de-commissioned, this may involve the removal of components.

The person carrying out the work is also required to make arrangements with users of the work location and ensure their safety throughout the process.

Note: This national occupational standard (Ref ID M26) belongs to SummitSkills – the Sector Skills Council for the Building Services Engineering Sector.

EUSDSG3.43

Decommission heating & ventilation systems, equipment and components

Performance criteria

You must be able to:

- P1 liaise with other persons at appropriate points within the de-commissioning process to minimise disturbance to work routines
- P2 check that conditions within the systems or components will permit safe de-commissioning
- P3 de-commission systems or components using tests and procedures which comply with industry requirements
- P4 take precautionary actions to ensure that de-commissioned systems or components do not prove a safety hazard
- P5 check that the de-commissioned systems and components are left safe, in line with industry requirements

EUSDSG3.43

Decommission heating & ventilation systems, equipment and components

Knowledge and understanding

You need to know and understand:

- K1 the importance of confirming the system functions, and the outcomes of suspending the operation of the system
- K2 the need to liaise with others whose procedures or routines may be affected by the suspension of the system operation
- K3 the potential hazards that could arise from de-commissioning activities and the checks to be carried out before de-commissioning takes place
- K4 de-commissioning procedures for temporary and permanent de-commissioning of systems, including organisational requirements
- K5 the precautions to ensure that de-commissioned systems do not prove a safety hazard, and the necessary measures to prevent systems being brought into operation, including using the correct safety and warning notices
- K6 how to safely collect and dispose of system contents that may be hazardous to health or harmful to the environment
- K7 how to complete systems de-commissioning records
- K8 system contents requiring recovery for re-use or disposal
- K9 the operating and working principles of the system to be decommissioned
- K10 what action to take when normal emptying or shut off mechanisms do not operate

EUSDSG3.43

Decommission heating & ventilation systems, equipment and components

Developed by Energy and Utility Skills

Version number 1

Date approved February 2010

Indicative review date February 2012

Validity Current

Status Imported

Originating organisation SummitSkills

Original URN DSG3.43

Relevant occupations Engineering; Science and Engineering Technicians

Suite Down Stream Gas

Key words decommission, heating, ventilation, systems, equipment, components